

OFFICE USE ONLY
 Log No. 4274
 Permit No. _____
 Basin 12

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32067

1. OWNER ALAN SCHROEDER ADDRESS AT WELL LOCATION 1540 EAST VALLEY GARDNERVILLE
 MAILING ADDRESS CASTAIC, CA

2. LOCATION SW 1/4 NE 1/4 Sec 35 T 13 N R 20 E DOUGLAS County
 PERMIT NO. 23-245-73 Subdivision Name EAST VALLEY
Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY		0	18	18
SANDS / GRAVEL		18	52	34
SANDY CLAY / GRAVEL		52	79	27
SANDY CLAY		79	109	30
CLAY		109	120	11
SANDY CLAY		120	131	11
SAND / GRAVEL	✓	131	143	12
SANDY CLAY		143	166	23
SANDS / GRAVEL	✓	166	215	49
SANDY CLAY		215	220	5

8. WELL CONSTRUCTION
 Depth Drilled 220 Feet Depth Cased 220 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 100 Feet
10 5/8 Inches
 From 100 To 220 Feet
9 7/8 Inches

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>+1</u>	<u>220</u>

Perforations:
 Type perforation FACTORY SLOTTED
 Size perforation 3 x 3/32
 From 200 feet to 220 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 220 feet

9. WATER LEVEL
 Static water level 51 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDDCO EXPLORATION, INC Contractor
 Address 7780 CURRY RD Contractor
FALLON, NV 89406
 Nevada contractor's license number 27673
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1997
 Signed David Reid
 By driller performing actual drilling on site or contractor
 Date 9-14-95

Date started 9-12, 1995
 Date completed 9-13, 1995

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>257</u>	<u>—</u>	<u>2</u>