

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32064

1. OWNER DARR CONSTRUCTION ADDRESS AT WELL LOCATION 154 E VALLEY RD
 MAILING ADDRESS GARDNERVILLE, NV GARDNERVILLE, NV

2. LOCATION NW 1/4 NE 1/4 Sec. 35 T. 13 N. R. 20 E. DOUGLAS County
 PERMIT NO. 23-293-01 Subdivision Name EAST VALLEY
Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY		0	6	6
SAND		6	10	4
SANDY CLAY		10	38	28
SAND/GRAVEL		38	55	17
SANDY CLAY		55	68	13
SAND/GRAVEL		68	82	14
SANDY CLAY/GRAVEL		82	141	82
SAND/GRAVEL		141	176	15
SANDY CLAY/GRAVEL		176	280	64
SANDY CLAY/SAND BEDS	✓✓	280	300	20

8. WELL CONSTRUCTION
 Depth Drilled 300 Feet Depth Cased 300 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 5/8 Inches 0 Feet 50 Feet
9 7/8 Inches 50 Feet 300 Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>+1</u>	<u>300</u>

Perforations:
 Type perforation FACTORY SLOTTED
 Size perforation 3 x 3/32
 From 280 feet to 300 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 300 feet

9. WATER LEVEL
 Static water level 73 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDDCO EXPLORATION, INC Contractor
 Address 7780 CURRY RD. Contractor
FALLON, NV 89406
 Nevada contractor's license number issued by the State Contractor's Board 27673
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1997
 Signed Dave J. Reed
 By driller performing actual drilling on site or contractor
 Date 9-20-95

Date started 9-14, 1995
 Date completed 9-19, 1995

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>25+</u>	<u>-</u>	<u>1 1/2</u>

RECEIVED
 95091-3 AM 11:16
 STATE ENGINEERING OFFICE