

OFFICE USE ONLY
 Log No. 49350
 Permit No. _____
 Basin. 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32067

1. OWNER DON HALL ADDRESS AT WELL LOCATION LOT 8
 MAILING ADDRESS GLEN BROOK, NV WILDFLOWER CT
GARDNERVILLE

2. LOCATION SE 1/4 NE 1/4 Sec 35 T 13 N R 20 E County DOUGLAS
 PERMIT NO. 23-472-43 Subdivision Name WILDFLOWER

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY/GRAVEL		0	5	5
CEMENTED GRAVEL/ROCKS		5	54	49
SANDY CLAY		54	82	28
SANDY CLAY/GRAVEL		82	93	10
SANDY GRAVEL		93	115	22
SANDY CLAY		115	205	90
CLAY		205	235	30
SANDY CLAY		235	246	11
CLAY		246	252	6
SANDY CLAY/GRAVEL		252	255	3
SAND/GRAVEL	✓	255	268	13
CLAY		268	270	2

8. WELL CONSTRUCTION
 Depth Drilled 270 Feet Depth Cased 270 Feet

HOLE DIAMETER (BIT SIZE)
 From To
10 5/8 Inches 0 Feet 50 Feet
9 7/8 Inches 50 Feet 270 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>+1</u>	<u>270</u>

Perforations:
 Type perforation FACTORY SLOTTED
 Size perforation 3 x 3/32
 From 270 feet to 250 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 270 feet

9. WATER LEVEL
 Static water level 95 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDDCO EXPLORATION, INC
 Address 7780 CURRY RD
FALLOON, NV 89406
 Nevada contractor's license number issued by the State Contractor's Board 27673
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1997
 Signed Dave J. Paul
 Date 8-29-95

Date started 8-21, 1995
 Date completed 8-28, 1995

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Air</u>	<u>257</u>	<u>-</u>	<u>1</u>

RECEIVED
 95 AUG 30 AM 10:27
 STATE ENGINEERS OFFICE