WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49252
Permit No.
Basin IRS

NOTICE OF INTENT NO. 27531

1. OWNER DECARLO CUSTOM HOMES
MAILING ADDRESS MINDEN, NV
ADDRESS AT WELL LOCATION 1931 BORDA
GARDNERVILLE

2. LOCATION SW ¼ NE ¼ Sec. 36 T. 13 N/S R. 20 E. DOUGLAS County
PERMIT NO. — (Issued by Water Resources) 23-472-55 (Parcel No.) WILDFLOWER (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY / GRAVEL		0	7	7
CEMENTED SAND / GRAVEL		7	22	15
SAND / GRAVEL		22	75	53
SANDY CLAY / GRAVEL		75	88	13
CLAY		88	140	52
SANDY CLAY / GRAVEL		140	243	103
FRACTURED BASALT		243	257	14
BASALT & GRAVEL		257	305	47
SANDY CLAY		305	358	53
CLAY (GRAY)		358	453	95
SANDY CLAY		453	520	67
CLAY		520	598	78
SAND	✓	598	606	9
CLAY		606	628	22
CLAY		628	665	37
SAND	✓✓	665	669	4
CLAY		669	673	4
SAND / CLAY	✓✓✓	673	680	7

RECEIVED 1995 AUG 30 AM 10:27 STATE ENGINEER'S OFFICE

Date started 8-3, 1995
Date completed 8-17, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR	25+	—	4

8. WELL CONSTRUCTION
Depth Drilled 675 Feet Depth Cased 675 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	50 Feet
9 7/8 Inches		50 Feet	675 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1	675

Perforations:
Type perforation FACTORY SLOTTED
Size perforation 3 x 3/32
From 635 feet to 675 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 675 feet

9. WATER LEVEL
Static water level 250 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature WARM °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EDDCO EXPLORATION, INC. (Contractor)
Address 7780 CURRY RD. (Contractor)
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 27673
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726
Signed Paul J. Moody (By driller performing actual drilling on site or contractor)
Date 8-17-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627