

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 26994

1. OWNER Dennis Conway ADDRESS AT WELL LOCATION  
MAILING ADDRESS 3590 Center Dr  
Carson City Nev

2. LOCATION NW 1/4 SW 1/4 Sec 8 T 14 N/S R 20 E Douglas County  
PERMIT NO. 13-040-06 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sticky clay reddish</u>		<u>0</u>	<u>20</u>	<u>20</u>
<u>DG</u>		<u>20</u>	<u>80</u>	<u>60</u>
<u>Soft granite fractured</u>	<u>*</u>	<u>80</u>	<u>140</u>	<u>60</u>

8. WELL CONSTRUCTION  
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)  
From 9 7/8 Inches To 0 Feet 140 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>.13</u>	<u>.188</u>	<u>71</u>	<u>140</u>

Perforations:  
Type perforation Factory Milled  
Size perforation 3/32

From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From 120 feet to 140 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes,  No Seal Type:  
Depth of Seal 50  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
From 50 feet to 140 feet

Date started 5-8, 1995  
Date completed 5-12, 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20</u>		<u>1</u>

9. WATER LEVEL  
Static water level 80 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature Cold °F Quality Clean

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Enloe Drilling Contractor  
Address P.O. Box 1345 Contractor  
Dayton Nev 89403

Nevada contractor's license number issued by the State Contractor's Board 4739 A  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1450

Signed La A. Enloe  
By driller performing actual drilling on site or contractor  
Date May 16 1995