

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 49258  
 Permit No. 105  
 Basin. \_\_\_\_\_

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22066  
1502 STEVE CT  
MINDEN, NV

1. OWNER FORSTEDT CONST. CO. ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS S. LAKE TAHOE, CA

2. LOCATION SE 1/4 SE 1/4 Sec 27 T. 14 N. R. 20 E. DOUGLAS County  
 PERMIT NO. 21-153-05 HIGHPOINTE Subdivision Name  
 Issued by Water Resources Parcel No. \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND/SMALL GRAVEL		0	44	44
SANDY CLAY		44	61	17
SAND/GRAVEL		61	64	3
SANDY CLAY		64	171	107
SAND		171	189	18
SANDY CLAY		189	196	7
SAND	✓	196	209	13
SANDY CLAY		209	244	35
CLAY		244	262	18
SAND	✓✓	262	270	8
CLAY		270	274	4
SAND	✓	274	280	6

8. WELL CONSTRUCTION  
 Depth Drilled 280 Feet Depth Cased 280 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 5/8 Inches 0 Feet 50 Feet  
9 7/8 Inches 50 Feet 280 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>+1</u>	<u>280</u>

Perforations:  
 Type perforation FACTORY SLOTTED  
 Size perforation 3 X 3/32  
 From 260 feet to 280 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 280 feet

9. WATER LEVEL  
 Static water level 115 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name EDDCO EXPLORATION, INC Contractor  
 Address 7780 CURRY RD Contractor  
FALLON NV 89410  
 Nevada contractor's license number 27673 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1997  
 Signed David Reid  
 By driller performing actual drilling on site or contractor  
 Date 9-7-95

Date started 8-29 19 95  
 Date completed 9-6 19 95

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>25+</u>	<u>—</u>	<u>2</u>

RECEIVED  
 95 OCT - 3 AM 11:45  
 WATER RESOURCES OFFICE