

Log No. 49259
 Permit No. 105
 Basin 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 76592

1. OWNER DENNIS CLARK CONST. ADDRESS AT WELL LOCATION 1407 KING PL. MINDEN, NV
 MAILING ADDRESS MINDEN, NV

2. LOCATION SW 1/4 SW 1/4 Sec 27 T 14 N R 20 E DOUGLAS County
 PERMIT NO. 21-160-20 JOHNSON LANE Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND		0	15	15
SANDY CLAY		15	26	11
SAND	✓	26	134	108
SANDY CLAY		134	144	10
COURSE SAND	✓	144	153	9
SANDY CLAY		153	155	2
COURSE SAND	✓	155	158	3
SANDY CLAY		158	160	2

8. WELL CONSTRUCTION

Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>10 5/8</u> Inches	<u>0</u> Feet <u>50</u> Feet
<u>9 7/8</u> Inches	<u>50</u> Feet <u>160</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>11.5</u>	<u>.188</u>	<u>0</u>	<u>160</u>

Perforations:
 Type perforation FACTORY
 Size perforation 3 x 3/32
 From 140 feet to 160 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 160 feet

Date started 9-25, 1995
 Date completed 9-27, 1995

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>25+</u>		<u>1</u>

9. WATER LEVEL

Static water level 38' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EDDCO EXPLORATION, INC Contractor
 Address 7780 CURRY RD. FALLON, NV 89406 Contractor

Nevada contractor's license number issued by the State Contractor's Board 27673
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1997

Signed David J. Reil
 By driller performing actual drilling on site or contractor
 Date 9-27-95

RECEIVED
 95 OCT 10 AM 11:46
 DIVISION OF WATER RESOURCES