

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20827

1. OWNER J.B. Coast ADDRESS AT WELL LOCATION 6035 Sudge St. Carson City
 MAILING ADDRESS _____
 2. LOCATION NE 1/4 NW 1/4 Sec 14 T 15 N/S R 20 E Carson City County _____
 PERMIT NO. 10-083-08 Parcel No. _____ Subdivision Name _____
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>DG Sand Gravel cemented</u>		<u>0</u>	<u>70</u>	<u>70</u>
<u>Soft Rock</u>		<u>70</u>	<u>220</u>	<u>150</u>
<u>Saturated</u>	<u>165</u>			
<u>u</u>	<u>200</u>			

8. WELL CONSTRUCTION
 Depth Drilled 220 Feet Depth Cased 220 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 220 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>+1</u>	<u>220</u>

Perforations:
 Type perforation Factory Milled
 Size perforation 3/32
 From 200 feet to 220 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 220 feet

9. WATER LEVEL
 Static water level 160 feet below land surface
 Artesian flow NA G.P.M. _____ P.S.I. _____
 Water temperature 68 °F Quality Good

Date started Feb 1 1995
 Date completed Feb 3 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25</u>		<u>1 hr</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Enlo Drilling Co. Contractor
 Address PO Box 1345 Dayton Nev. Contractor
 Nevada contractor's license number issued by the State Contractor's Board 47290
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 590
 Signed Ch. Hill
 By driller performing actual drilling on site or contractor
 Date Feb 4 95