WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49267
Permit No.
Basin 168

NOTICE OF INTENT NO. 26987

1. OWNER Foley Const
MAILING ADDRESS 329 Woodside Ct Dayton, Nev
ADDRESS AT WELL LOCATION 228 Baylor Dayton

2. LOCATION NE ¼ NE ¼ Sec. 9 T. 16 N/S R. 22 E. Lyon County
PERMIT NO. (Issued by Water Resources) 19-142-18 (Parcel No.) Dayton Valley Ranches (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Top soil		0	2	2
Cemented cobble & clay		2	90	88
Saturated gravel	*	90	160	70

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
9 7/8	0	160

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1	160

Perforations:
Type perforation Factory Milled
Size perforation 3/32
From feet to feet
From 140 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 160 feet

9. WATER LEVEL
Static water level 90 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Enloe Drilling (Contractor)
Address P.O. Box 1345 (Contractor)
Dayton
Nevada contractor's license number issued by the State Contractor's Board 41739 A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1480
Signed Lee A. Enloe (By driller performing actual drilling on site or contractor)
Date May 5 1996

Date started April 27, 1995
Date completed May 1, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		2

RECEIVED JUN -8 P2:49 STATE ENGINEER

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627