

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27676

1. OWNER Gerard Lannivez ADDRESS AT WELL LOCATION 2290S Carnegie Drive Reno Nevada
 MAILING ADDRESS 620 Thang St Reno

2. LOCATION SW 1/4 SE 1/4 Sec 7 T 17 N S R 20 E Washoe County
 PERMIT NO. 050-115-04
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|-----------------------|--------------|------|-----|------------|
| Top Soil | | 0 | 6 | 6 |
| Large Grained w/ clay | | 6 | 42 | 36 |
| Clay, brown, Sandy | | 42 | 65 | 23 |
| Gravel to 1" | | 65 | 89 | 24 |
| Clay + Gravel | | 89 | 142 | 53 |
| Gravel 2" plus | | 142 | 125 | 3 |

8. WELL CONSTRUCTION
 Depth Drilled 125 Feet Depth Cased 125 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12 Inches 0 Feet 12-0 Feet
6 1/8 Inches 12-0 Feet 12-5 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>6 5/8</u> | <u>12.97</u> | <u>0.188</u> | <u>0</u> | <u>120</u> |
| <u>5</u> | <u>9.66</u> | <u>0.188</u> | <u>117</u> | <u>125</u> |

Perforations:
 Type perforation factory mill slot
 Size perforation 3/32
 From 100 feet to 125 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Concrete Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 120 feet

9. WATER LEVEL
 Static water level 109 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name M. Scan Drilling Contractor
 Address 2290 Pioneer Drive Contractor
Reno, Nevada 89509
 Nevada contractor's license number issued by the State Contractor's Board 14170
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1261
 Signed Steve [Signature]
 By driller performing actual drilling on site or contractor
 Date 5/12/95

Date started 10-26, 1995
 Date completed 11-28, 1995

7. WELL TEST DATA

| TEST METHOD: | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--|-----------|-------------------------------|--------------|
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift | <u>30</u> | <u>25</u> | <u>25</u> |
| <u>Pumpup Safford G</u> | | <u>75'</u> | |