

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26744

1. OWNER David Baldassare ADDRESS AT WELL LOCATION Dayton, NV
 MAILING ADDRESS SAME

2. LOCATION NE 1/4 SW 1/4 Sec. 20 T. 17 N/S R. 22 E. Storey County
 PERMIT NO. N/A | 03-304-03 | Mark Twain Subdivision Name
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Hand

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulders & Soil		0	6	6
Hard Boulders		6	82	76
Black shale		82	156	74
HARD Black shale		156	282	126
HARD Black shale with cracks		282	340	58

'95 JUN 29 12:10
 REGISTERED
 STATE ENGINEERS OF NV

8. WELL CONSTRUCTION
 Depth Drilled 340 Feet Depth Cased 340 Feet

HOLE DIAMETER (BIT SIZE)
 From To
10 5/8 Inches 0 Feet 60 Feet
8 1/2 Inches 60 Feet 340 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>3/16</u>	<u>+1</u>	<u>340</u>

Perforations:
 Type perforation Touch cut
 Size perforation 1 1/4 x 6" x 5 ROWS
 From 320 feet to 340 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 0-50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 340 feet

9. WATER LEVEL
 Static water level 230 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.F.
 Water temperature _____ °F Quality _____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Developed</u>	<u>2 hrs</u>	<u>AND</u>
<u>produced</u>	<u>about</u>	<u>25 gpm.</u>

Date started 5-30, 1995
 Date completed 6-10, 1995

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Leach Drilling Inc Contractor
 Address P.O. Box 599 Contractor
Silver Springs, NV 89429

Nevada contractor's license number issued by the State Contractor's Board 0031841
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1877

Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 6/26/95