

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20675

1. OWNER Michael Mountjoy ADDRESS AT WELL LOCATION 11465 Silver Ln
 MAILING ADDRESS 303 GROSSH Dayton, NY 89403 STAGECOACH, NV 89429
 2. LOCATION SW 1/4 NE 1/4 Sec 17 T 17 N/S R 23 E Lyon County
 PERMIT NO. 416 Apr 19-392-01 Parcel No. _____ Subdivision Name Silver Valley Subdivision
 Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP SOIL		0	3	3
BROWN Clay		3	65	62
SAND & GRAVEL	X	65	70	5
BROWN Clay		70	97	27
SAND & GRAVEL	X	97	103	6
BROWN Clay		103	118	15
SAND & GRAVEL	X	118	125	7
SAND & GRAVEL	X	125	147	22
BROWN Clay		147	150	3

'95 JUN -5 P258
 STATE ENGINEERS OFF

8. WELL CONSTRUCTION
 Depth Drilled 150 Feet Depth Cased 150 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12 Inches 0 Feet 53 Feet
8 Inches 0 Feet 150 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>19.11</u>	<u>.188</u>	<u>0</u>	<u>150</u>

Perforations:
 Type perforation Factory SLOT
 Size perforation 7/32
 From 110 feet to 140 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 53 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 58 feet below land surface
 Artesian flow N/A G.P.M. _____ P.S.I. _____
 Water temperature COLD °F Quality UNKNOWN

Date started 4 Oct 1994
 Date completed 10 Oct 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>205</u>	<u>40 FT</u>	<u>1</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name BARNES Well Drilling Contractor
 Address 7061 Hwy 50E Contractor
Dayton NV 89403
 Nevada contractor's license number issued by the State Contractor's Board 0030040
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1634
 Signed Bobby L Barnes
 By driller performing actual drilling on site or contractor
 Date 10 Oct 1994