WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49286
Permit No.
Basin 102

NOTICE OF INTENT NO. 26045

1. OWNER Brooke Mohun / Brown
MAILING ADDRESS P.O. Box 97
Silver Springs NV 89429
ADDRESS AT WELL LOCATION 3360 E. 3rd St.
S.S. NV 89429

2. LOCATION SE ¼ NW ¼ Sec. 9 T. 17 N/S R. 25 E. Lyon County
PERMIT NO. 17-172-10 (Issued by Water Resources) | 17-172-10 (Parcel No.) | Lake Side (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface Sand		0	5	5
Clay		5	18	12
Sand, fine		18	40	22
Clay		40	48	8
Sand Coarse		48	61	13
Sand fine	121	61	121	60
Sand Coarse (Some gravel)	138	121	138	17

'95 JUN 12 P12:11
STATE ENGINEERS OFF.

Date started 6/1/95, 19
Date completed 6/3/95, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
60-65	1½	hrs

8. WELL CONSTRUCTION
Depth Drilled 138 Feet Depth Cased 139 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	1 Feet	138 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.	1.88	+1	138

Perforations:
Type perforation Torch Cut
Size perforation 3/16 x 6 x 5 sq pcs
From 128 feet to 138 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 51'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 51 feet to 138 feet

9. WATER LEVEL
Static water level 38 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature C °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Daniel W. Penn (Contractor)
Address PO 599 (Contractor)
SS NV 89429
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876
Signed Daniel Penn (By driller performing actual drilling on site or contractor)
Date 6/3/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627