

OFFICE USE ONLY
 Log No. 49288
 Permit No.
 Basin. 102

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31980

1. OWNER Ambrose Pippinger ADDRESS AT WELL LOCATION 776 S. Rimington
 MAILING ADDRESS 3501 Prestige Ln Silver Springs, NV
Bakersfield, Ca 93313

2. LOCATION SW 1/4 SE 1/4 Sec 18 T. 17 N R. 25 W Lyon County
 PERMIT NO. 17-302-08 Sagebrush #2

Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	38	38'
Clay		38	55	17'
fine sand		55	60	5'
Clay & sand		60	85	15'
8 Sand & gravel	X	85	100	15'

8. WELL CONSTRUCTION

Depth Drilled 100 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)

From	To
10 Inches	0 Feet <u>52</u> Feet
6 Inches	0 Feet <u>100</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.77</u>	<u>.188</u>	<u>0</u>	<u>100</u>

Perforations:
 Type perforation machined
 Size perforation 3 x 1/8

From 90 feet to 98 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 52' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL

Static water level: 40' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature: cold °F Quality: good

Date started July 31 1995
 Date completed Aug 5 1995

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>3450 rpm</u>	<u>30</u>	<u>10'</u>	<u>4</u>

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Vernon Cannon Jr. Contractor
 Address 4555 Hwy 50 W Contractor
Silver Springs, NV 89429

Nevada contractor's license number 23317
 issued by the State Contractor's Board

Nevada driller's license number issued by the 1455
 Division of Water Resources, the on-site driller.

Signed Vernon Cannon Jr.
 By driller performing actual drilling on site or contractor

Date Aug 9, 1995

RECEIVED
 95 AUG 10 AM 10:57
 STATE ENGINEERS OFFICE