

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26741

1. OWNER Bill Beto Sr ADDRESS AT WELL LOCATION Ten St
 MAILING ADDRESS Via-19th St
1994 Springfield 35 NV 89429 55 NV 89429
 2. LOCATION SE 1/4 NE 1/4 Sec. 30 T. 17 N/S R. 25 County Labontan
 PERMIT NO. 1A Issued by Water Resources 117-472-00 Parcel No. 11837 Subdivision Name 11837

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mod

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	16	6
Sand Clay		16	12	6
Sand coarse & fine		12	58	46
Clay, Silt		58	82	64
Clay Sand Stone		82	107	25
Clay Silt		107	115	8
Clay	131	115	131	16
Sand Gravel 3/8" 3/8" holes	146	131	146	15

8. WELL CONSTRUCTION
 Depth Drilled 146 Feet Depth Cased 147 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 146 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>1.28</u>	<u>71</u>	<u>146</u>

Perforations:
 Type perforation Tenon Cut
 Size perforation 3/16 x 6 x 5 round pass
 From 136 feet to 146 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 50 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 50 feet to 146 feet

9. WATER LEVEL
 Static water level 39 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature C °F Quality OK, Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Jason J. Dillingham Contractor
 Address PO 599 Contractor
55 NV 89429
 Nevada contractor's license number issued by the State Contractor's Board 0031841
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876
 Signed W. Denise
 By driller performing actual drilling on site or contractor
 Date 6/13/95

Date started 6/12/95, 19_____
 Date completed 6/13/95, 19_____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>55-60</u>		<u>4 mo</u>