Bobby

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49295
Permit No.
Basin 102

NOTICE OF INTENT NO. 26043

1. OWNER James & Koline Smith
MAILING ADDRESS 1530 Deer St
Silver Springs, NV. 89429

ADDRESS AT WELL LOCATION (1530 DEER ST.)
1530 Deer St Canyon
SS NV

2. LOCATION NW ¼ NE ¼ Sec. 30 T. 17 N/S R 25 E. Pea County
PERMIT NO. N/A (Issued by Water Resources) 17-143-08 (Parcel No.) Riverside #1 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface Sand		0	10	10
Course, Fine Sand		10	62	52
Course Gravels		62	81	19
Grey, black silt		81	123	42
Course Sand	123	123	134	11
Course Sand, Gravels	150	134	150	16

'95 JUN 12 P12:11
STATE ENGINEERS OFF.

Date started 5/24/95, 19
Date completed 5/26/95, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
45-50	2 hrs	

8. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased 151 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	1 Feet	150 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.	1.88	+1	150

Perforations:
Type perforation Torch Cut
Size perforation 3/16 x 6" x 5 rows per
From 139 feet to 159 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 54'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 54 feet to 150' feet

9. WATER LEVEL
Static water level 35' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature C °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Peach Drilling Inc (Contractor)
Address PO 599 (Contractor)
SS NV 89429
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 6/3/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627