WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49298
Permit No.
Basin 179

NOTICE OF INTENT NO. 28861

1. OWNER Gary Webb
MAILING ADDRESS HC Box 32205
Ely, NV 89301

ADDRESS AT WELL LOCATION 6 miles north of Ely

2. LOCATION SW ¼ SE ¼ Sec. 15 T. 17 N/S R. 63 E. White Pine County
PERMIT NO. N/A (Issued by Water Resources) | 30 (Parcel No.) | Cross Timbers (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	5	5
Sand & Gravel		5	30	25
Clay & Gravel		30	40	10
Sand & Gravel		40	45	5
Clay & Gravel		45	50	5
Sand & Gravel		50	55	5
Clay & Gravel		55	60	5
Water Bearing Sand & Gravel	x	60	70	10
Sand & Clay		70	75	5
Water Bearing Sand & Gravel	x	75	100	25
Clay & Gravel		100	124	24

Date started May 22, 1995
Date completed May 23, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	55	1

8. WELL CONSTRUCTION
Depth Drilled 124 Feet Depth Cased 124 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	124 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	124

Perforations:
Type perforation Factory
Size perforation 1/8" x 2½" 6 rows
From 64 feet to 124 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 124 feet

9. WATER LEVEL
Static water level 65 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Christiansen Drilling, Inc. (Contractor)
Address 557 Ely Avenue (Contractor)
Ely, Nv 89301
Nevada contractor's license number issued by the State Contractor's Board 14790
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 641
Signed Jerald D. Christiansen (By driller performing actual drilling on site or contractor)
Date May 24, 1995

'95 MAY 26 A11:40 STATE ENGINEER'S OFFICE

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627