

OFFICE USE ONLY
 Log No. 49305
 Permit No. _____
 Basin 102

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27562

1. OWNER DAN BARBER ADDRESS AT WELL LOCATION 2100 FIR ST
 MAILING ADDRESS Box 242 Yerington NV 89447 Yerington Springs
 2. LOCATION SE 1/4 SE 1/4 Sec 35 T. 18 N/S R. 24 E LYON County
 PERMIT NO. _____ LAKE VIEW ESTATES
 Issued by Water Resources APR 15 1995 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP SOIL		0	3	3
CEMENT GRAVEL		3	43	40
YELLOW CLAY & GRAVEL		43	143	100
SOLID ROCK		143	145	2
FRACTURED ROCK	<input checked="" type="checkbox"/>	145	152	7
CLAY FRACTURED ROCK	<input checked="" type="checkbox"/>	152	182	30
SAND & GRAVEL	<input checked="" type="checkbox"/>	182	197	15

8. WELL CONSTRUCTION
 Depth Drilled 197 Feet Depth Cased 197 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 53 Feet
 From 8 Inches To 197 Feet
 Casing Schedule

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 7/8	14.11	.188	0	197

Perforations:
 Type perforation Factory Slots
 Size perforation 3/32
 From 167 feet to 187 feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 5.3
 Neat Cement
 Placement Method: Pumped Poured
 Cement Grout Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 140 feet below land surface
 Artesian flow NO G.P.M. _____ P.S.I. _____
 Water temperature COLD °F Quality UNKNOWN

Date started 12 March 19 95
 Date completed 19 March 19 95

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>14</u>	<u>15</u>	<u>2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name BARNES Well Drilling Contractor
 Address 7061 Hwy 50 E Dayton NV 89403 Contractor
 Nevada contractor's license number 0030040 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1634
 Signed Bobby L Barnes
 By driller performing actual drilling on site or contractor
 Date 19 March 1995