WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49312
Permit No.
Basin 087

NOTICE OF INTENT NO. 32806

1. OWNER Nick Creveling
MAILING ADDRESS 1445 Upton Way
Sparks, Nevada 89431

ADDRESS AT WELL LOCATION 5039 Pleasant View Drive
Sparks

2. LOCATION NW ¼ NW ¼ Sec. 1 T 19 N/S R 20 E Washoe County
PERMIT NO. 005422 (Issued by Water Resources) 30-204-01 (Parcel No.) Sunset View Rancho (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Overburden | | 0' | 10' | |
| Basalt | | 10' | 125' | |
| Gray Clay | | 125' | 135' | |
| Basalt | | 135' | 160' | |
| ¼" Gravel + H20 | 160' | 160' | 165' | 5' |
| Basalt | | 165' | 190' | |
| Gravel + H20 | 190' | 190' | 230' | 40' |
| Fracture + H20 | 230' | 230' | 245' | 15' |
| Gray Clay | | 245' | 253' | |

Date started 8/22, 19 95
Date completed 8/30, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| Approx. | 20 | 230' | 2 Hours |

8. WELL CONSTRUCTION
Depth Drilled 253' Feet Depth Cased 253' Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 12¼ Inches | | 0 Feet | 20 Feet |
| 9 7/8 Inches | | 20 Feet | 60 Feet |
| 8 ½ Inches | | 60 Feet | 253 Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 | 14 | 188 | +1 | 253 |

Perforations:
Type perforation Mill Slot
Size perforation 1/8 x 3
From 190 feet to 253 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'+
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 253 feet

9. WATER LEVEL
Static water level 169 feet below land surface
Artesian flow none G.P.M. none P.S.I.
Water temperature 59 °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Miller & Sons Drilling (Contractor)
Address P.O. Box 8056 (Contractor)
Reno, Nevada 89507
Nevada contractor's license number issued by the State Contractor's Board 37915
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1743
Signed (By driller performing actual drilling on site or contractor)
Date 8-31-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627