

OFFICE USE ONLY  
 Log No. 49351  
 Permit No. 076  
 Basin                     

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 23820  
300 FAMILY COURT  
FERNLEY NV

1. OWNER RALPH & PHYLLIS GIVEN ADDRESS AT WELL LOCATION 300 FAMILY COURT  
 MAILING ADDRESS 15448 CARRIE DRIVE FERNLEY NV  
GRASS VALLEY CA 95949

2. LOCATION SW 1/4 NE 1/4 Sec 15 T. 20 N# R 24 E LYON County  
 PERMIT NO. 21-165-14C  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
OVER BURDEN		0	4	
FINE VOL SANDS		4	15	
MULTI COLORED COARSE VOL ROCK		15	36	
STICKY BROWN CLAY		36	65	
STICKY GREEN BROWN CLAY		65	71	
VOL SAND & GRAVEL		71	74	
TAN & GREEN CLAY		74	78	
GREEN CLAY STICKY		78	129	
GRAY CLAY STICKY		129	162	
GREEN VOL ROCK WITH PURPLE CLAY		162	181	
GREEN VOL ROCK FRACTURED		181	237	
GREEN CLAY ZONES WITH COARSE SANDS & GRAVEL LAYERS VOL		237	273	

8. WELL CONSTRUCTION:  
 Depth Drilled 273 Feet Depth Cased 273 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 0 Feet 273 Feet  
 Inches Feet  
 Inches Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>1252</u>	<u>188</u>	<u>+1 1/2</u>	<u>273</u>

Perforations:  
 Type perforation FACTORY SAWED  
 Size perforation 3/32 x 3"  
 From 253 feet to 233 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 105  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 273 feet to 105 feet

9. WATER LEVEL  
 Static water level: DRY feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A.S.A.P. PUMP & WELL SERVICE, INC. Contractor  
 Address 1800 1/2 FRAZER AVENUE Contractor  
SPARKS, NV 89431

Nevada contractor's license number issued by the State Contractor's Board: 35387A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1511  
 Signed Randy Welch  
 By driller performing actual drilling on site or contractor  
 Date 6-28-95

Date started 6-15, 1995  
 Date completed 6-20, 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>0</u>	<u>01:20</u>	<u>67</u>



2177

23

Handwritten scribbles or marks at the bottom left.

