

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23818
325 FAMILY COURT
FERNLEY NV

1. OWNER NADA FINTZEL ADDRESS AT WELL LOCATION 325 FAMILY COURT
 MAILING ADDRESS 2138 RIZZO DRIVE FERNLEY NV
SPARKS, NV 89431

2. LOCATION SW $\frac{1}{4}$ NE $\frac{1}{4}$ Sec. 15 T 20N N/S R. 24E E. LYON County
 PERMIT NO. 21-165-12 FAMILY COURT Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TAN CLAY		0	3	
VOL SANDS & CLAY		3	25	
FINE SANDS		25	39	
RED CLAY WITH GREEN BROWN VOL ROCK		39	42	
GREEN YELLOW TAN CLAY WITH GREEN BROWN YELLOW VOL SANDS & GRAVELS		42	112	
STICKY GREEN CLAY		112	122	
VOL SAND		122	124	
STICKY GREEN CLAY		124	173	
VOL GRAVELS WITH GREEN CLAY LAYERS		173	200	
BROWN WHITE VOL ROCK FRACTURED		200	215	
GREEN RED VOL ROCK		215	220	

8. WELL CONSTRUCTION
 Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 220 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>188</u>	<u>+1 1/2</u>	<u>220</u>

Perforations:
 Type perforation FACTORY SAWED
 Size perforation 3/32 x 3"
 From 180 feet to 200 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 105

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 220 feet to 105 feet

Date started 6-9-95
 Date completed 6-14-95

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

DATE	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>JUN 10 1995</u>	<u>9+</u>		<u>2</u>

9. WATER LEVEL
 Static water level 95 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name ASAP PUMP & WELL SERVICE, INC. Contractor
 Address 1800 1/2 FRAZER AVENUE Contractor
SPARKS, NV 89431
 Nevada contractor's license number issued by the State Contractor's Board 35387A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1511
 Signed Randy Welch By driller performing actual drilling on site or contractor
 Date 6-19-95

NOV 23 1952

RECEIVED