

OFFICE USE ONLY
 Log No. 49362
 Permit No. _____
 Basin. 0927

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT N. 32555

1. OWNER PAUL PATTERSON ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P.O. Box 50317 11770 Plata Mesa
Reno, Nevada 89513 Reno, Nevada 89506
 2. LOCATION SW 1/4 NE 1/4 Sec. 25 T. 21N N/S R. 18 E Washoe County
 PERMIT NO. 086-171-12 Silver Knolls
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
WELL DEEPENING				
Well depth 55 feet				
Rusty sand, yield 1.5GPM		54	55	1
Sandy brown clay		55	65	10
Brown clay		65	70	5
Soft zone, granite sands	X	70	71	1
Brown clay		71	105	34
Soft zone, granite sands	X	105	109	4
Brown clay		109	114	15
Granite sands	X	114	123	9
Brown clay		123	124	1
Granite sands	X	124	130	6
Soft brown sandy clay		130	131	1

8. WELL CONSTRUCTION
 Depth Drilled 131 Feet Depth Cased 131 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
6 1/8 Inches 55 Feet 131 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5" OD		.188	0	131

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x .3 x 5 around
 From 85 feet to 125 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal deepening Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 55 feet to 131 feet

Date started 7-26-95, 19____
 Date completed 7-26-95, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	21		

9. WATER LEVEL
 Static water level: 58 feet below land surface
 Artesian flow: _____ G.P.M. 21 P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. Box 12370 Contractor
Reno, Nevada 89510
 Nevada contractor's license number issued by the State Contractor's Board: 22549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 923
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date July 26, 1995