WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49364
Permit No.
Basin 084

NOTICE OF INTENT NO. 27257

1. ~~OWNER~~ Consultant: GROUNDWATER RESOURCES CONSULTANTS, INC.
MAILING ADDRESS 6200 E 14th Street, Suite A200
Tucson, AZ 85711

Owner: RICHARD MILLER
ADDRESS AT WELL LOCATION Right Hand Canyon Road
Reno, NV 89510

2. LOCATION SW ¼ SE ¼ Sec. 18 T 22N N/S R 22 E Washoe County
PERMIT NO. AREA C (Issued by Water Resources) 077-310-11 (Parcel No.) Palomino Valley (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown clay with some volcanic gravels		1	6	5
Fine sandy clay		6	18	12
Brown clay		18	67	49
Volcanic gravels		67	72	5
Reddish brown clay & sands		72	115	43
Soft zone, multi-color sand	X	115	121	6
Reddish brown clays & sands		121	133	12
Soft zone	X	133	136	3
Brown clay with volcanic gravels & sands		136	150	14

Date started 8-15-95, 19
Date completed 8-16-95, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
16.6		

8. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	150 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	150

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 105 feet to 145 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 51 foot
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 51 feet to 150 feet

9. WATER LEVEL
Static water level 52 feet below land surface
Artesian flow G.P.M. 16.6 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date August 18, 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627