

OFFICE USE ONLY  
 Log No. 49369  
 Permit No. 176  
 Basin 1  
 NOTICE OF INTENT NO. 28624

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER John Johnson ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 870 Sherman Way Richards Way  
Reno, Nev. 89506 Fernley, Nev. 89408  
 2. LOCATION NW 1/4 NE 1/4 Sec. 27 T. 20 N/S R. 25 E. Churchill County  
 PERMIT NO. 21-481-15  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Gravel & Boulders		0	60	60
Gravel & Clay		60	80	20
Gravel & Sand		80	140	60
Clay & Gravel		140	260	120
Brown Clay		260	340	80
Gravel	XX	340	390	50

'95 MAY 31 AM 10:40  
 STATE ENGINEERS OF I

8. WELL CONSTRUCTION  
 Depth Drilled 390 Feet Depth Cased 390 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 50 Feet  
8-1/2 Inches 50 Feet 390 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	0	390

Perforations:  
 Type perforation Mill-Cut  
 Size perforation 1/8"  
 From 350 feet to 390 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50ft.  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 390 feet

9. WATER LEVEL  
 Static water level 287 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cool °F Quality Unknown

Date started April 18, 1995  
 Date completed April 28, 1995

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name PARSONS DRILLING, INC. Contractor  
 Address P.O. BOX 1265 Contractor  
FALLON, NEVADA 89407-1265  
 Nevada contractor's license number issued by the State Contractor's Board 29046  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1454  
 Signed Damon Parson  
 By driller performing actual drilling on site or contractor  
 Date 5-24-95



21/11/11

2011