REPORT NO. 95.31

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 49372
PERMIT NO.
BASIN

NOTICE OF INTENT NO. 28524

OWNER Steve Taylor
MAILING ADDRESS 26063 Ave 17 Ste B Madera, Ca 93638

ADDRESS OF WELL 11590 Chesapeake
Reno, Nv 89506 Lemmon Valley

2. WELL LOCATION SE 1/4 SE 1/4 SEC. 15 T 21N R 19 E Washoe COUNTY

PERMIT NO. PARCEL NO 80-332-14 SUBDIVISION NAME

3. TYPE OF WORK
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Overburden		0	3	3
Sandy loam		3	17	14
Hard Pan		17	36	19
Loose DG & clay with some gravel		36	218	182

'95 JUN -2 A9:20
STATE LIBRARY

Notes: Bottom full of native material

Date Started 5/22/95 Date Completed 5/23/95

7. WELL TEST DATA

TEST METHOD [ ] Bailer [X] Pump [ ] Air Lift

	GPM	DRAWDOWN	TIME (HRS)
	10	119	1

8. WELL CONSTRUCTION

Depth Drilled 218 Depth Cased 174

HOLE DIAMETER (BIT SIZE)
10 5/8 Inches 0 Feet 218 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D.	Weight/Ft	Wall Thickness	From	To
6 5/8	12.92	.188	+1	174

PERFORATIONS:
Type Perforation factory Size Perforation 3/32 x 3
From 134 Feet to 174 Feet
From Feet to Feet
From Feet to Feet

SURFACE SEAL: [X] Yes [ ] No
Seal Depth 50'
PLACEMENT METHOD: [ ] Pumped [X] Poured

SEAL TYPE:
[ ] Neat Cement
[ ] Cement Grout
[X] Concrete Grout

GRAVEL PACKED: [X] Yes [ ] No
From 50 Feet to 174 Feet

9. WATER LEVEL
Static Water Level 74 Feet Below Land Surface
Artesian Flow GPM PSI
Water Temperature F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service, Inc
Address 625 Spice Islands Dr Ste L
Sparks, Nv 89431

NV. CONTRACTOR'S LIC. NO. 15291
DRILLER'S LIC. NO. ON SITE 1132

Signed
By driller performing actual drilling on site or contractor

Dated 5/26/95