

OFFICE USE ONLY
 Log No. 49373
 Permit No. _____
 Basin 092B

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO.29560

1. OWNER Dave Harvey ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 8550 Cassilis dr. 11305 Fir
Reno, Nevada 89506 Reno, Nevada 89506

2. LOCATION NE 1/4 SE 1/4 Sec 23 T 21 N/S R 19 E Washoe County
 PERMIT NO. _____ Issued by Water Resources Parcel No. 080-278-04 Subdivision Name Lemmon Valley

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	3	3
Brown Sand		3	7	4
Brown Sandy clay		7	41	34
Brown clay with DG sands mixed		41	88	47
Granite Sands (no water) X		88	91	3
Brown clay with DG sands mixed		91	116	25
Granite Sands with streak of clay		116	133	17
Weathered Granite (green)		133	156	23
Fracture (no water) X		156	157	1
Weathered Granite (green)		157	163	6
Fracture (no water) X		163	164	1
Weathered Granite (green)		164	179	15
Gray Granite weathered		179	191	12
Hard gray granite		191	218	27
Softer granite Weathered.		218	231	13
Reddish brown clay streak		231	232	1
Gray granite		232	270	38
Green Granite		270	277	7

8. WELL CONSTRUCTION
 Depth Drilled 277 Feet Depth Cased 277 Feet

HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 50 Feet
8 5/8 Inches 50 Feet 147 Feet
6 1/8 Inches 147 Feet 277 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	147
5" OD		.188	137	277

Perforations:
 Type perforation Factory Sawn slot
 Size perforation 3/32 x 3 x 5 around

From 277 feet to 257 feet
 From 217 feet to 207 feet } 5" feet
 From 167 feet to 157 feet } feet
 From 140 feet to 100 feet } 6" feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 50

Placement Method: Pumped
 Poured

Gravel Packed: Yes No
 From 50 feet to 147 feet

9. WATER LEVEL
 Static water level 82 feet below land surface
 Artesian flow _____ G.P.M. 12 P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling Inc. Contractor
 Address P.O. Box 12370 Contractor
Reno, Nevada 89510

Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date June 20, 1995

Date started 6/14/95, 19_____
 Date completed 6/15/95, 19_____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
12		