WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49374
Permit No.
Basin 0928

NOTICE OF INTENT NO. 27253

Consultant:

~~1. OWNER~~ Victor & Vicki Pugh

MAILING ADDRESS P.O. Box 51251
Sparks, Nevada 89434

ADDRESS AT WELL LOCATION 10525 Birch
Lemmon Valley Reno, Nevada 89506

2. LOCATION SE ¼ NW ¼ Sec. 26 T. 21N N/S R. 19E E. Washoe County

PERMIT NO. (Issued by Water Resources) | 080-283-05 (Parcel No.) | Lemmon Valley (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	1	1
Brown Clay		1	3	2
Brown Sand		3	4	1
Brown Clay		4	18	14
Light green clay		18	22	4
granite Sands		22	23	1
Brown clay		23	69	46
Brown Sandy Clay		69	81	12
Soft Zone		81	88	7
Brown Clay		88	119	31
Soft Zone with Clay streaks		119	136	17
Soft Brown Sandy Clay		136	140	4

'95 MAY 15 P2:15
STATE ENGINEER'S OFF

Date started 5-5-95, 19
Date completed 5-5-95, 19

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15		

8. WELL CONSTRUCTION

Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	50 Feet
8 5/8 Inches	50 Feet	140 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	140

Perforations:
Type perforation Factory Sawed Slot
Size perforation 3/32 x 3 x 5 around
From 115 feet to 135 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured

Seal Type:
☐ Neat Cement
☒ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL

Static water level 63 feet below land surface
Artesian flow G.P.M. 15 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling Inc. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, Nevada 89510

Nevada contractor's license number issued by the State Contractor's Board 22549

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed [signature] (By driller performing actual drilling on site or contractor)

Date May 9, 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627