

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 99382
 Permit No. _____
 Basin 985

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 29554

1. OWNER Mike Browning ADDRESS AT WELL LOCATION 13000 Campo Rico Lane
 MAILING ADDRESS 5515 Wedekind rd. Sparks, Nevada 89436
Reno, Nevada 89431
 2. LOCATION NW 1/4 SW 1/4 Sec 1 T. 21N N/S R. 20E E Washoe County
 PERMIT NO. 076-281-15 Spanish Springs
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	1	1
Brown clay with gravels		1	13	12
Brown sandy clay with some gravels		13	74	61
Brown clay		74	105	31
Black to gray Volcanic Rock		105	130	25
Fracture no water	X	130	132	2
Black hard volcanic rock		193	240	147
Fracture no water		240	245	5
Black volcanic rock		245	251	6
Weathered green granite		251	302	53
Fracture		302	310	8
Weathered green & gray granite		310	330	20
Fracture Granite		330	340	10
Gray & Green Granite		340	350	10

8. WELL CONSTRUCTION
 Depth Drilled 350 Feet Depth Cased 350 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 50 Feet
8 5/8 Inches 50 Feet 350 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	350

Perforations:
 Type perforation Factory Sawn Slot
 Size perforation 3/32 x 3 x 5 around
 From 345 feet to 325 feet
 From 310 feet to 300 feet
 From 260 feet to 250 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped
 Poured
 Gravel Packed: Yes No
 From 50 feet to 350 feet

9. WATER LEVEL
 Static water level: 200 feet below land surface
 Artesian flow: _____ G.P.M. 25+ P.S.I.
 Water temperature: cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling Inc. Contractor
 Address P.O. Box 12370 Contractor
Reno, Nevada 89510
 Nevada contractor's license number issued by the State Contractor's Board: 22549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 923
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date June 8, 1995

Date started 6/5/95, 19_____
 Date completed 6/7/95, 19_____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25+</u>		