

OFFICE USE ONLY
 Log No. 49383
 Permit No. _____
 Basin. _____
 NOTICE OF INTENT NO. 32567

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER ROY ARNESON ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 3155 Wedekind Road 270 Descanso Lane
Sparks, Nevada 89431 Sparks, Nevada 89436
 2. LOCATION SW $\frac{1}{4}$ SE $\frac{1}{4}$ Sec 2 T. 21N N/S R. 20E E Washoe County
 PERMIT NO. 076-282-26 Spanish Springs
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown clay w/decomposed granite sands		1	3	2
Brown clay & boulders		3	6	3
Brown DG sands		6	21	15
Brown clay, some DG sands		21	93	72
Gray clays		93	189	96
Brown clays		189	244	55
Reddish brown volcanic rock		244	261	17
Brown volcanic rock		261	289	28
Fracture rock(app 8 GPM) X		289	294	5
Brown & red volcanic rock		294	355	61
Fracture rock X		355	367	12
Brown volcanic rock		367	375	8

8. WELL CONSTRUCTION
 Depth Drilled 375 Feet Depth Cased 375 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 50 Feet
8 5/8 Inches 50 Feet 375 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	375

 Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 270 feet to 310 feet
 From 330 feet to 370 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 feet Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 375 feet

RECEIVED
 AUG 30 AM 10:26
 STATE ENGINEERS OFFICE

Date started 8-23-95, 19_____
 Date completed 8-28-95, 19_____
 7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
12		

9. WATER LEVEL
 Static water level 181 feet below land surface
 Artesian flow 12 G.P.M. 12 P.S.I.
 Water temperature cold °F Quality clear
 10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number 22549
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed Wayne C. [Signature]
 By driller performing actual drilling on site or contractor
 Date August 29, 1995