REPORT NO. 95.32

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 49384
PERMIT NO.
BASIN 084

NOTICE OF INTENT NO. 28523

1. OWNER John Ragsdale
MAILING ADDRESS 55 Lonesome Polecat Carson City, Nv 89704

ADDRESS OF WELL Sky Canyon Ct
Sparks, Nv 89436 Palomino Valley

2. WELL LOCATION NW 1/4 NE 1/4 SEC. 7 T 21N R 21E E Washoe COUNTY

PERMIT NO. PARCEL NO 76-190-27 SUBDIVISION NAME

3. TYPE OF WORK
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Loose sand		0	13	13
Green DG		13	26	13
Light green DG		26	74	48
Hard granite with soft DG streaks		74	160	86
Hard granite		160	389	229
Broken granite with brown clay		389	391	2
Black & gray rock with quartz chips		391	394	3
Brown clay layer & black rock chips,		394		
quartz		394	397	3
Black, green & brown rock with some		397		
quartz & some clay		397	421	24
Hard non-fractured granite		421	591	170
Hard granite, frequent fractures		591	741	150
Hard, broken granite	X	741	780	39

Notes :

'95 JUN -9 AM 11:26
STATE ENGINEER

Date Started 5/19/95 Date Completed 6/5/95

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [X] Air Lift

	GPM	DRAWDOWN	TIME (HRS)
720'	15		
740'	20		

8. WELL CONSTRUCTION

Depth Drilled 780 Depth Cased 780

HOLE DIAMETER (BIT SIZE)

10 5/8 Inches 0 Feet 50 Feet
8 1/2 Inches 50 Feet 780 Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D.	Weight/Ft	Wall Thickness	From	To
6 5/8	12.92	.188	+1	780

PERFORATIONS:

Type Perforation factory Size Perforation 3/32 x 3
From 740 Feet to 760 Feet
From Feet to Feet
From Feet to Feet

SURFACE SEAL: [X] Yes [ ] No
Seal Depth 432'

SEAL TYPE:
[ ] Neat Cement
[ ] Cement Grout
[X] Concrete Grout

PLACEMENT METHOD: [ ] Pumped [X] Poured

GRAVEL PACKED: [X] Yes [ ] No
From 348 Feet to 780 Feet

9. WATER LEVEL

Static Water Level 682 Feet Below Land Surface
Artesian Flow GPM PSI
Water Temperature F Quality

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service, Inc
Address 625 Spice Islands Dr Ste L
Sparks, Nv 89431

NV. CONTRACTOR'S LIC. NO. 15291 DRILLER'S LIC. NO. ON SITE 1132

Signed [signature]
By driller performing actual drilling on site or contractor

Dated 6/6/95