

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 238231

1. OWNER TOM & LESLIE BOWEN ADDRESS AT WELL LOCATION ANTELOPE VALLEY ROAD
 MAILING ADDRESS 10185 SHILOH DRIVE
RENO NV 89506
 2. LOCATION NE 1/4 NE 1/4 Sec 5 T 22 N# R 19 E WASHOE County
 PERMIT NO. 079-332-21 Issued by Water Resources Parcel No. Red Rock Estates #369 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
GREEN YELLOW BROWN FINE DG SANDS		0	18	
COARSE DG SANDS BROWN YELLOW WHITE TAN WITH TAN CLARY		18	185	
GREEN YELLOW WHITE BROWN COARSE SANDS WITH TAN CLARY ZONES		185	373	
	X			
373 TD				

8. WELL CONSTRUCTION
 Depth Drilled 373 Feet Depth Cased 373 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
 10 5/8 Inches 0 Feet 55 Feet
 8 1/2 Inches 55 Feet 373 Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.96	188	+1 1/2	373

Perforations:
 Type perforation FACTORY SAWED
 Size perforation 3/32 x 3"
 From 373 feet to 353 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 55
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 370 feet to 55 feet

9. WATER LEVEL
 Static water level 200 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality _____

Date started 5-15 19 95
 Date completed 5-19 19 95

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	10+		10

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A.S.A.P. PUMP & WELL SERVICE INC Contractor
 Address 1800 1/2 FRAZER AVENUE Contractor
SPARKS, NV 89431
 Nevada contractor's license number issued by the State Contractor's Board 0035387-A
 Nevada driller's license number issued by the 1511 Division of Water Resources, the on-site driller
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date 5-24-95