WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49391
Permit No.
Basin 094

NOTICE OF INTENT NO. 29551

Consultant:

1. ~~OWNER~~ John & Susan Lampman
MAILING ADDRESS 400 Ramsey Way
Reno, Nevada 89506

ADDRESS AT WELL LOCATION
Gooding Drive
Reno, Nevada 89506

2. LOCATION ~~NW~~ SE ¼ ~~NW~~ NE ¼ Sec. 87 T. 22N N/S R. 19E E. Washoe County

PERMIT NO. (Issued by Water Resources) | 079-382-40 (Parcel No.) | Red Rock Estates #90 parcel 2 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	2	2
Dark Brown Clay		2	8	6
Brown Sandy Clay		8	45	37
Gray Clay		45	118	73
Soft Zone	X	118	121	3
Gray Clay		121	156	35
Soft Zone	X	156	160	4
Gray Sandy Clay		160	182	22
Soft Zone	X	182	196	14
Gray Clay		196	200	4

95 MAY 15 P2:15 STATE ENGINEER

Date started 5-8-95, 19
Date completed 5-9-95, 19

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		

8. WELL CONSTRUCTION

Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	50 Feet
8 5/8 Inches	50 Feet	200 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	200

Perforations:
Type perforation Factory Sawed Slot
Size perforation 3/32 x 3 x 5 around
From 200 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 200 feet

9. WATER LEVEL

Static water level 57 feet below land surface
Artesian flow G.P.M. 25 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling Inc. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, Nevada 89510

Nevada contractor's license number issued by the State Contractor's Board 22549

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed Gary C. Hedgren (By driller performing actual drilling on site or contractor)

Date May 11, 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627