WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

27Acft

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49396
Permit No.
Basin 093

NOTICE OF INTENT NO. 27255

1. OWNER Steve Brehm
MAILING ADDRESS 7210 Marlin Drive
Reno, Nevada 89506

ADDRESS AT WELL LOCATION
1340 Antelope Valley Rd.
Reno Nevada 89506

2. LOCATION SW ¼ NE ¼ Sec. 27 T 22N N/S R 19E E Washoe County
PERMIT NO. (Issued by Water Resources) 079-450-0252 (Parcel No.) Antelope Valley Red Rock Est #1 (Subdivision Name) Lot 1

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	11	11
gravels & Brown Sand		11	16	5
Boulders & gravel sand		16	18	2
Brown sand		18	21	3
Brown sandy clay		21	61	40
Soft zone (no water)	X	61	65	4
Brown sandy clay with some granite gravels		65	123	58
Weathered Granite	X	123	127	4
Fracture Granite		127	155	28
Gray granite		155	163	8
Fracture granite	X	163	171	8
Gray Granite		171	175	4

'95 JUN 22 AM 10:59
STATE ENGINEER

Date started 6/12/95, 19
Date completed 6/13/95, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
21		

8. WELL CONSTRUCTION
Depth Drilled 175 Feet Depth Cased 175 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	50 Feet
8 5/8 Inches	50 Feet	175 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	175

Perforations:
Type perforation Factory Sawed Slot
Size perforation 3/32 x 3 x 5 around
From 130 feet to 170 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 175 feet

9. WATER LEVEL
Static water level 121 feet below land surface
Artesian flow G.P.M. 21 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling Inc (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, Nevada 89510

Nevada contractor's license number issued by the State Contractor's Board 22549

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed [signature] (by driller performing actual drilling on site or contractor)
Date June 20, 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627