

OFFICE USE ONLY  
 Log No. 47317  
 Permit No. 09274  
 Basin                     

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this report as carefully as possible.  
 Nevada State Water Resources Division, P.O. Box 634, Reno, NV 89400

NOTICE OF INTENT NO. 31847  
 BUSINESS WELL LOCATION: 1255 ANTELOPE VALLEY ROAD  
RENO, NV

1. OWNER LARS & MICHELLE STERNER  
 MAILING ADDRESS 145 ERIC AVENUE  
SPARKS, NEVADA 89431  
 COUNTY WASHOE  
 PERMIT NO. 079-420-07  
 SUBDIVISION NAME Red Rock Estates #366

3. WORK PERFORMED  
 New Well     Replace     Recondition  
 Deepen     Abandon     Other.....  
 4. PROPOSED USE  
 Domestic     Irrigation     Test  
 Municipal/Industrial     Monitor     Stock  
 5. WELL TYPE  
 Cable     Rotary     RVC  
 Air     Other MUD.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TAN YELLOW BROWN FINE SANDS		0	47	
TAN YELLOW GREEN DG FIRM WITH TAN CLAY ZONES		47	315	
STICKY GREEN CLAY WITH SMALL DG SAND ZONES		315	470	
DG SANDS GREEN YELLOW WHITE BROWN		470	485	
STICKY GREEN CLAY		485	525	
GREEN BROWN YELLOW VOL ROCK FRACTURED		525	650	
TD - 650				

8. WELL CONSTRUCTION  
 Depth Drilled 650 Feet    Depth Cased 650 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From                      To  
10 5/8 Inches    0 Feet    90 Feet  
8 1/2 Inches    90 Feet    650 Feet  
 \_\_\_\_\_ Inches    \_\_\_\_\_ Feet    \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1 1/2	650

 Perforations:  
 Type perforation FACTORY SAWED  
 Size perforation 3/32 x 3"  
 From 580 feet to 600 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes     No    Seal Type:  
 Depth of Seal 54 \_\_\_\_\_  
 Neat Cement  
 Placement Method:  Pumped     Cement Grout  
 Poured     Concrete Grout  
 Gravel Packed:  Yes     No  
 From 650 feet to 54 feet

9. WATER LEVEL  
 Static water level 200 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F    Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name A.S.A.P. PUMP & WELL SERVICE INC  
 Contractor  
 Address 1800 1/2 FRAZER AVENUE  
 Contractor  
SPARKS, NEVADA 89431  
 Nevada contractor's license number issued by the State Contractor's Board 35387A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1511  
 Signed Kenny Welch  
 By driller performing actual drilling on site or contractor  
 Date 9-7-95

7. WELL TEST DATA

TEST METHOD:  Bailer     Pump     Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+		2

RECEIVED  
 SEP 11 PM 2:44  
 WATER RESOURCES DIVISION