

OFFICE USE ONLY
 Log No. 49398
 Permit No. _____
 Basin. 084

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27250

1. OWNER Gerald & Marian DeGirolamo ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 631 Hamilton Street 14955 state Route 445
San Francisco, California 94134 Reno, Nevada 89510

2. LOCATION NE 1/4 NW 1/4 Sec. 24 T. 22N N/S R. 20E E Washoe County
 PERMIT NO. 076-272-07 Parcel No. 24-2-0-4 Subdivision Name Palomino Valley Unit 5

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil with gravels & some boulders		0	1	1
Brown clay with some gravels & sand		1	9	8
Brown clay		9	47	38
Brown clay with fine sands		47	56	9
Brown sandy clay with gravels		56	88	32
rusty brown clay		88	96	8
Brown volcanic rock		96	130	34
Soft zone (5GPM)	X	130	134	4
Brown volcanic rock		134	151	17
White Volcanic rock		151	167	16
Fracture		167	168	1
White volcanic Rock		168	176	8
Brown volcanic rock		176	182	6
Brown volcanic rock with some red		182	199	17
Fracture rock		199	216	17
Reddish brown rock		216	225	9

8. WELL CONSTRUCTION
 Depth Drilled 225 Feet Depth Cased 225 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 50 Feet
8 5/8 Inches 50 Feet 225 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	225

Perforations:
 Type perforation Factory Sawn Slot
 Size perforation 3/32 x 3 x 5 around
 From 140 feet to 180 feet
 From 200 feet to 220 feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50
 Neat Cement
 Cement Grout
 Concrete Grout

Placement Method: Pumped
 Poured

Gravel Packed: Yes No
 From 50 feet to 225 feet

Date started 5/30/95, 19____
 Date completed 5/31/95, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40+		

9. WATER LEVEL
 Static water level 62 feet below land surface
 Artesian flow _____ G.P.M. 40+ P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling Inc. Contractor
 Address P.O. Box 12370 Contractor
Reno, Nevada 89510

Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada driller's license number issued by the Division of Water Resources, and on-site driller 923

Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date June 5, 1995