

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24916

1. OWNER Richard J. Williams ADDRESS AT WELL LOCATION Lot 2, Elkhart Bldg  
 MAILING ADDRESS P.O. Box 511, Elko, Nevada 89801  
 2. LOCATION 1/4 Sec. 26 T. 35 S. R. 57 E. Elko County  
 PERMIT NO. 220020257 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Gr. /</u>		<u>0</u>	<u>3</u>	
<u>Sandy clay</u>		<u>3</u>	<u>5</u>	
<u>Loose yellow</u>		<u>5</u>	<u>32</u>	
<u>Loose clay</u>		<u>32</u>	<u>33</u>	
<u>Loose</u>		<u>33</u>	<u>51</u>	
<u>Sandy clay</u>		<u>51</u>	<u>156</u>	
<u>clay to this base</u>		<u>156</u>		

8. WELL CONSTRUCTION  
 Depth Drilled 128 Feet Depth Cased 128 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
10 Inches \_\_\_\_\_ Feet 128 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/4</u>	<u>12.92</u>	<u>1.45</u>	<u>71</u>	<u>128</u>

Perforations:  
 Type perforation Tooth  
 Size perforation 1/2"  
 From 158 feet to 178 feet Per Telon w/Driller  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 25  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 25 feet to 118 feet

9. WATER LEVEL  
 Static water level 105 feet below land surface  
 Artesian flow + G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
 Water temperature cool °F Quality Good

Date started 4-25 1981  
 Date completed 4-27 1981

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>30</u>	<u>20</u>	<u>2</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Raymond J. King Contractor  
 Address 1020 1/2 St. Elko Contractor  
 Nevada contractor's license number issued by the State Contractor's Board CA4410  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1590  
 Signed Raymond J. King  
 By driller performing actual drilling on site or contractor  
 Date 5-20-81