WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49437
Permit No.
Basin 049

NOTICE OF INTENT NO. 29932

1. OWNER Bill CRANE
MAILING ADDRESS 19 W Hannon Blvd
SAGINAW MI 98602

ADDRESS AT WELL LOCATION Lot 1-D Elko Summit Dr.

2. LOCATION SE ¼ NE ¼ Sec. 25 T. 34 N/S R. 55 E. Elko County

PERMIT NO. (Issued by Water Resources) | Lot 1-D (Parcel No.) | Elko Summit Estates (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Shale		0	42	42
Gray Shale		42	63	21
Light Brown Shale		63	70	7
Brown Shale	X	70	71	1
White Sandstone		71	84	13
Tan Color Shale		84	98	14
Dark Brown Shale	X	98	99	1
Tan Color Shale		99	101	2
Hard Rock		101	102	1
White Sandstone		102	108	6
Light Gray Shale		108	150	42

RECEIVED
95 AUG 31 AM 11:20
STATE ENGINEERS OFFICE

Date started 8-18, 1995
Date completed 8-20, 1995

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50 +		2

8. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	150 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	188	+2	150

Perforations:
Type perforation Slots
Size perforation 3/16 x 3"
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 55
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 55 feet to 150 feet

9. WATER LEVEL
Static water level 50 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Fertig Drilling Co (Contractor)
Address PO Box 525 (Contractor)
Elko NV 89801

Nevada contractor's license number issued by the State Contractor's Board 31904

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584

Signed [signature]
By driller performing actual drilling on site or contractor

Date 8-28-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627