WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49447
Permit No.
Basin 070

NOTICE OF INTENT NO. 29189

1. OWNER Larry & Dawn Maden
MAILING ADDRESS Po Box 2112
Winnemucca N.V. 89445

ADDRESS AT WELL LOCATION 3850 Kitty Hank Lane

2. LOCATION ___ ¼ ___ ¼ Sec. 24 T 35 N/S R 37 E Humboldt County
PERMIT NO. N/A (Issued by Water Resources) 14-101-04 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	15	
Cemented Rock		15	25	
Clay		25	30	
Clay and Sand		30	40	
Rock W/S Clay		40	60	
Clay W/S Sand		60	84	
Cemented Rock		84	130	

JUN 28 '95 10:55 RECEIVED STATE ENGINEERS OFFICE

Date started JUNE 18, 19 95
Date completed JUNE 19, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15	N/A	4Hr.
Plugged by Well log 127225		

8. WELL CONSTRUCTION
Depth Drilled 130 Feet Depth Cased 130 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
60 Inches	0 Feet	130 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"	N/A	.188	+1	130

Perforations:
Type perforation FACTORY
Size perforation 1/8" By 3"
From 110 feet to 130 feet
From ___ feet to ___ feet
From ___ feet to ___ feet
From ___ feet to ___ feet
From ___ feet to ___ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 130 feet to 50 feet

9. WATER LEVEL
Static water level 66 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name DAVE McNINCH (Contractor)
Address 8005 McNICH RD. (Contractor)
WINNEMUCCA, NV. 89445
Nevada contractor's license number issued by the State Contractor's Board 5437
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 730
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 6-28-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627