

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTEREST NO. 32065

1. OWNER JIM KENT CONSTRUCTION ADDRESS AT WELL LOCATION 997 FARRIER CT GARDNERVILLE
MAILING ADDRESS GARDNERVILLE, NV

2. LOCATION SE 1/4 SE 1/4 Sec 13 T 12 N S R 20 E DOUGLAS County
PERMIT NO. 29-442-12 RUHENSTROTH Subdivision Name
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY/GRAVEL		0	110	110
SAND/GRAVEL		110	154	44
CEMENTED GRAVEL		154	162	8
SANDY CLAY		162	172	10
SAND/GRAVEL		172	175	3
CEMENTED GRAVEL/SAND		175	236	61
SAND/GRAVEL	✓	236	244	8
CEMENTED GRAVEL/BASALT	✓	244	250	6
SAND/GRAVEL	✓	250	259	9
SANDY CLAY	✓	259	260	1

RECEIVED
95 DEC 18 11:05
STATE ENGINEER'S OFFICE

8. WELL CONSTRUCTION
Depth Drilled 260 Feet Depth Cased 260 Feet
HOLE DIAMETER (BIT SIZE)
From To
10 5/8 Inches 0 Feet 50 Feet
9 7/8 Inches 50 Feet 260 Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>+1</u>	<u>260</u>

Perforations:
Type perforation FACTORY SLOTTED
Size perforation 3 x 3/32
From 240 feet to 260 feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 50 feet to 260 feet

9. WATER LEVEL
Static water level 145 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature COLD °F Quality GOOD

Date started 11-10 1995
Date completed 11-17 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>AIR</u>	<u>25+</u>	<u>—</u>	<u>2 HRS</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EDDCO EXPLORATION, INC Contractor
Address 7780 CURRY RD Contractor
FALLON, NV 89406
Nevada contractor's license number 27673
issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on site driller 1997
Signed David J. Reid
By driller performing actual drilling on site or contractor
Date 11-17-95