

OFFICE USE ONLY  
 Log No. 49477  
 Permit No. \_\_\_\_\_  
 Basin 105

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24720  
 ADDRESS AT WELL LOCATION 1665 TOWER RD  
GARDNERVILLE

1. OWNER BR CONSTRUCTION  
 MAILING ADDRESS GARDNERVILLE, NV

ADDRESS AT WELL LOCATION 1665 TOWER RD  
GARDNERVILLE

2. LOCATION SE 1/4 NW 1/4 Sec. 2 T. 12 N. R. 20 E County  
 PERMIT NO. 25-160-21 Parcel No. \_\_\_\_\_  
 Issued by Water Resources \_\_\_\_\_

DOUGLAS County  
EAST VALLEY Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel / sandy clay		0	12	12
Sandy clay / sand		12	36	24
Sandy clay		36	56	20
Gravel / sandy clay		56	84	28
Sandy clay some gravel		84	90	6
gravel / some sandy clay		90	128	38
Sandy clay		128	133	5
gravel / some sandy clay		133	138	5
Sandy clay		138	161	23
gravel / short clay		161	180	19

8. WELL CONSTRUCTION  
 Depth Drilled 180 Feet Depth Cased 180 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 5/8 Inches 0 Feet 100 Feet  
9 7/8 Inches 100 Feet 180 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>+2</u>	<u>180</u>

Perforations:  
 Type perforation Factory Slotted  
 Size perforation 3 x 3/32  
 From 160 feet to 180 feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  
 Depth of Seal 100  Cement Grout  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From 100 feet to 180 feet

9. WATER LEVEL  
 Static water level 32 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name EDDCO EXPLORATION, INC  
 Contractor  
 Address 7780 CURRY RD  
 Contractor  
FALLON, NV 89406  
 Nevada contractor's license number issued by the State Contractor's Board 27673  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535  
 Signed Jerald V. [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 11-22-95

Date started 11-17, 1995  
 Date completed 11-21, 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20+</u>	<u>—</u>	<u>1</u>