

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 88929

1. OWNER JOHN LYNCH ADDRESS AT WELL LOCATION 638 CLYDEDALE  
 MAILING ADDRESS GARDNERVILLE, NV GARDNERVILLE

2. LOCATION SE 1/4 SW 1/4 Sec 24 T. 12 N. R. 20 E. DOUGLAS County  
 PERMIT NO. 29-520-44 RUBENSTROTH Subdivision Name  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MVD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY		0	14	14
CEMENTED GRAVEL / BOBELS		14	39	25
SAND / GRAVEL / BOBELS		39	93	44
CEMENTED GRAVEL	✓	93	134	51
SAND / GRAVEL	✓	134	150	16
CEMENTED GRAVEL	✓	150	164	14
SAND / GRAVEL	✓	164	171	7
CEMENTED GRAVEL	✓	171	180	9

8. WELL CONSTRUCTION

Depth Drilled 180' Feet Depth Cased 180' Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
<u>10 5/8</u>	<u>0</u>	<u>50</u>	<u>50</u>	<u>50</u>
<u>9 7/8</u>	<u>50</u>	<u>180</u>	<u>180</u>	<u>180</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>180</u>	<u>0</u>

RECEIVED  
 05 DEC 18 AM 11:05  
 STATE ENGINEERING OFFICE

Perforations:  
 Type perforation FALCONRY 3 x 3 1/2  
 Size perforation \_\_\_\_\_  
 From 180 feet to 160 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 180 feet to 50 feet

9. WATER LEVEL  
 Static water level 91 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD °F Quality GOOD

Date started 11-20 1995  
 Date completed 11-29 1995

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
<u>AIR</u>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
G.P.M.	<u>25+</u>	<u>—</u>	<u>2</u>
Draw Down (Feet Below Static)	<u>—</u>	<u>—</u>	<u>—</u>
Time (Hours)	<u>—</u>	<u>—</u>	<u>—</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name EDDCO EXPLORATION, INC Contractor  
 Address 7780 CURRY RD Contractor  
FALLON, NV 89406  
 Nevada contractor's license number issued by the State Contractor's Board 27673  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1997  
 Signed Don J. Paul  
 By driller performing actual drilling on site or contractor  
 Date 11-29-95