WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 4447
Permit No.
Basin 105

NOTICE OF INTENT NO. 28925

1. OWNER WESTLAND CONSTRUCTION
MAILING ADDRESS GARDNERVILLE
ADDRESS AT WELL LOCATION 619 APPALOOSA GARDNERVILLE

2. LOCATION SW ¼ SE ¼ Sec. 24 T. 12 N/S R. 20 E. DOUGLAS County
PERMIT NO. — (Issued by Water Resources) 29-520-15 (Parcel No.) RUHENSTROTH (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY/GRAVEL		0	4	4
CEMENTED GRAVEL		4	11	7
SAND/GRAVEL		11	56	45
SANDY CLAY		56	71	15
SAND GRAVEL		71	75	4
SANDY CLAY		75	82	7
CEMENTED GRAVEL		82	94	12
SANDY CLAY/GRAVEL		94	115	21
CEMENTED GRAVEL		115	150	35
SAND GRAVEL	✓	150	156	6
CEMENTED GRAVEL		156	180	24
SAND/GRAVEL	✓	180	187	7
CEMENTED GRAVEL		187	192	5
SAND/GRAVEL	✓	192	197	5
SANDY CLAY/GRAVEL		197	200	3

Date started 12-5, 19 95
Date completed 12-14, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR	15	—	2

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	50	Feet
9 7/8	Inches	50	Feet	200	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1	200

Perforations:
Type perforation FACTORY SLOTTED
Size perforation 3 x 3/32
From 180 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 110 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EDCO EXPLORATION, INC (Contractor)
Address 7780 CURRY RD (Contractor)
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 27673
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1997
Signed (By driller performing actual drilling on site or contractor)
Date 12-14-95

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 3/91) (O)-627