REPORT NO. 95.68

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 49478
PERMIT NO.
BASIN 100
NOTICE OF INTENT NO. 30850

1. OWNER Thomas & Holly McVicker
MAILING ADDRESS 17517 Northridge Reno, Nv 89506
ADDRESS OF WELL 17110 Hwy 395 North
Reno, Nv 89506

2. WELL LOCATION SE 1/4 SW 1/4 SEC. 29 T 21N R 18 E Washoe COUNTY

PERMIT NO. PARCEL NO 081-181-11 SUBDIVISION NAME

3. TYPE OF WORK
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Overburden & dirt		0	40	40
Clay & dirt		40	55	15
DG & dirt		55	70	15
Clay & DG		70	100	30
DG		100	119	19

Notes :

Date Started 12/5/95 Date Completed 12/6/95

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [X] Air Lift

	GPM	DRAWDOWN	TIME (HRS)
	50+		1

8. WELL CONSTRUCTION

Depth Drilled 119 Depth Cased 119

HOLE DIAMETER (BIT SIZE)
10 Inches 0 Feet 119 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D.	Weight/Ft	Wall Thickness	From	To
6 5/8	12.92	.188	+1	119

PERFORATIONS:
Type Perforation factory Size Perforation 3/32 x 3
From 99 Feet to 119 Feet
From Feet to Feet
From Feet to Feet

SURFACE SEAL: [X] Yes [ ] No
Seal Depth 52'
PLACEMENT METHOD: [X] Pumped [ ] Poured

SEAL TYPE:
[X] Neat Cement
[ ] Cement Grout
[ ] Concrete Grout

GRAVEL PACKED: [X] Yes [ ] No
From 52 Feet to 119 Feet

9. WATER LEVEL
Static Water Level 30 Feet Below Land Surface
Artesian Flow GPM PSI
Water Temperature cool F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service, Inc
Address 675 Edison Way
Reno, Nv 89502

NV. CONTRACTOR'S LIC. NO. 15291 DRILLER'S LIC. NO. ON SITE 1981

Signed Roger M Thrall
By driller performing actual drilling on site or contractor

Dated 12/7/95