WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49483
Permit No.
Basin 103

NOTICE OF INTENT NO. 81266

1. OWNER Albert & Carolyn Atkins
MAILING ADDRESS 1663 Quail Ln Carson City NV 89706
ADDRESS AT WELL LOCATION 1663 Quail Ln Carson City NV 89706

2. LOCATION NW ¼ NW ¼ Sec. 23 T. 15 N/S R. 20 E. Carson County
PERMIT NO. (Issued by Water Resources) Parcel No. 10-094-05 Subdivision Name Pinion Hills Area

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	3	3
Course DG Sands		3	145	142
Course Gray & White DG Sands		145	180	35
(Soft) Broken Granite Rusty Course Sands		180	220	40
Black Shale Broken Fractures		220	270	
Broken Fractures Course Lava Rocks Red & Black (Hard)	xxx	270	300	

Date started 12-8, 19 95
Date completed 12-12, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15	45	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11 1/4 Inches	0 Feet	300 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	300

Perforations:
Type perforation Mill Slot
Size perforation 3x3/32
From 280 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 55
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 55 feet to 300 feet

9. WATER LEVEL
Static water level 220 feet below land surface
Artesian flow G.P.M. 15 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Company (Contractor)
Address 5551 Hwy 50 E #3 (Contractor)
Carson City NV 89701
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L Hack (By driller performing actual drilling on site or contractor)
Date 12-13-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627