

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30705

1. OWNER Bill CRANE ADDRESS AT WELL LOCATION Elko Vista Dr  
 MAILING ADDRESS 19 W HANNUM BLVD. EAST END  
SAGINAW, MI 48603

2. LOCATION SW 1/4 NE 1/4 Sec 25 T 34 N/S R 55 E County Elko  
 PERMIT NO. Lot 5-B Subdivision Name Elko Summit Estates  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Loam		0	8	8
Clay Brown		8	24	16
Black shale		24	85	61
Brown shale	X	85	110	25
Black shale		110	125	15
White SANDSTONE		125	132	7
Gray shale		132	170	38
Brown shale	X	170	190	20

8. WELL CONSTRUCTION  
 Depth Drilled 190 Feet Depth Cased 190 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
10 Inches 0 Feet 190 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"	12.92	1.88	+2	190

Perforations:  
 Type perforation Slots  
 Size perforation 3/16 x 3"  
 From 170 feet to 190 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 51  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 51 feet to 190 feet

Date started 10-1 1995  
 Date completed 10-5 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>APP 15</u>		<u>3.5</u>

9. WATER LEVEL  
 Static water level 40' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Fertig Drilling Co Contractor  
 Address PO Box 525 Contractor  
Elko NV 87801

Nevada contractor's license number issued by the State Contractor's Board 31904  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584

Signed Shane Fertig  
 By driller performing actual drilling on site or contractor  
 Date 10-20-95