WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49493
Permit No.
Basin 071

NOTICE OF INTENT NO. 31032

1. OWNER Darren Ragan
MAILING ADDRESS 148-07 Van Diest Rd.
Winnemucca, NV 89445

ADDRESS AT WELL LOCATION
6385 Solar Drive
Winnemucca, NV 89445

2. LOCATION NW ¼ SE ¼ Sec. 12 T 35 (N/S) R 37 E Humboldt County

PERMIT NO. (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	2	2
Sand, gravel w/s cobbles		2	25	23
Sand, gravel w/s clay		25	40	15
Sand, gravel w/cobbles		40	50	10
Sand, gravel w/clay		50	55	5
Sand, gravel w/cobbles		55	60	5
Sand & Clay		60	110	50
Sand, gravel w/clay		110	115	5
Clay		115	125	10
Clay & cobbles		125	150	25
Sand & gravel w/clay		150	170	20

Date started December 13, 1995
Date completed December 14, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35		

8. WELL CONSTRUCTION
Depth Drilled 170 Feet Depth Cased 170 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	170 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	130

Perforations:
Type perforation Mill Slot
Size perforation 1/8 x 2 Double Row
From 130 feet to 170 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 170 feet

9. WATER LEVEL
Static water level 80 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co Inc. (Contractor)
Address P o Box 590 (Contractor)
Winnemucca, NV 89446

Nevada contractor's license number issued by the State Contractor's Board 015234

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1713

Signed [signature] (By driller performing actual drilling on site or contractor)
Date 12/14/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627