WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49498
Permit No.
Basin 106

NOTICE OF INTENT NO. 27140

1. OWNER Roger + Lisa Frankiewich
MAILING ADDRESS 4219 Dover Cir Cypress Ca. 90630
ADDRESS AT WELL LOCATION 931 Cavelti Pine Valley Gardenville Nev.

2. LOCATION NW ¼ SE ¼ Sec. 35 T. 11 N/S R. 21 E. Douglas County
PERMIT NO. none (Issued by Water Resources) | 35-310-25 (Parcel No.) | Pine Valley (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
alluvial small rock + brown clay		0	45	45
solid rock		45	380	335

at 275 ft a small amount of water was noticable. Then again at 370 a small amount more came in.

RECEIVED
95 AUG 25 AM 11:56
STATE ENGINEERS OFFICE

Date started July 22, 1995
Date completed Aug 23, 1995

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☑ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
6+	350	3 hrs.

8. WELL CONSTRUCTION
Depth Drilled 380 Feet Depth Cased 380 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 Inches	0 Feet	50 Feet
6 5/8 Inches	50 Feet	380 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		188	0	45
5 3/4		188	45	380

Perforations:
Type perforation factory new slott
Size perforation 3/32 x 3
From 270 feet to 290 feet
From 330 feet to 380 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50 ft
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☑ No
From — feet to — feet

9. WATER LEVEL
Static water level 220 feet below land surface
Artesian flow — G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Edmund Miller (Contractor)
Address Box 92 Smith Nev. 89430 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 32166
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718
Signed Edmund Miller (By driller performing actual drilling on site or contractor)
Date July 23 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627