

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27811

1. OWNER Tom Yturbe ADDRESS AT WELL LOCATION 1335 Old Foothill RD  
 MAILING ADDRESS P.O. Box 855 Gard. NV  
2ephyr Cave, 89448  
 2. LOCATION SE 1/4 NW 1/4 Sec 3 T 12 N/S R 19 E Douglas County  
 PERMIT NO. 7257-2585 Permit 60682 Kingsbury + Foothill Area Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Granite - Sand	X	0	80	
DG - Sand		80	150	
Sand Stone DG		150	230	
Granite DG		230	350	
Granite - Sand DG		350	400	
Small boulders periodically 0-400				
'95 MAY 31 AM 1:39 RECEIVED STATE ENGINEERS OFFICE				

8. WELL CONSTRUCTION  
 Depth Drilled 400 Feet Depth Cased 400 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 0 To 405 Feet  
12 1/4 Inches 0 Feet 405 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	9.5	.188	0	400

Perforations:  
 Type perforation Factory Perc Mill Slot  
 Size perforation 3 x 3/32  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 100' feet to 400' feet

9. WATER LEVEL  
 Static water level 31' feet below land surface  
 Artesian flow NO G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD °F Quality \_\_\_\_\_

Date started 5/5 1995  
 Date completed 5/20 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
AIR LIFT +	400 gpm		8-9 HRS

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Kawchack Drilling Inc. Contractor  
 Address P.O. Box 1359 Contractor  
Minden, NV 89423  
 Nevada contractor's license number issued by the State Contractor's Board 02126P  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1380  
 Signed Ed Kawchack  
 By driller performing actual drilling on site or contractor  
 Date 5/23/95