WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49504
Permit No.
Basin 108

NOTICE OF INTENT NO. 27280

1. OWNER Paul S. Tola
MAILING ADDRESS 999 OLD San Jose Rd. SP17 Soquel Calif 95073
ADDRESS AT WELL LOCATION 23 N. ByBee Ln. Yerington, Nev 89447

2. LOCATION NE ¼ SE ¼ Sec. 34 T. 14 N/S R. 26 E. Lyon County
PERMIT NO. Issued by Water Resources | 14-381-29 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top-Soil-Sandy		0	4	4
Coarse Sand-Gravel-Few Rocks		4	50	46
Coarse Sand-Gravel-Clay		50	56	6
Coarse Sand-Gravel		56	70	14
Coarse Sand-Gravel-Clay		70	82	12
Coarse Sand-Gravel		82	90	8
Clay-Coarse Sand-Gravel		90	113	23
Coarse Sand-Gravel-Clay		113	125	12
Clay-Sand		125	130	5
Coarse Sand-Gravel		130	150	20
Clay-Coarse Sand-Gravel		150	160	10
Coarse Sand-Gravel	X	160	184	24
Coarse Sand-Clay		184	188	4
Coarse Sand-Gravel-Clay		188	198	10
Brown Clay		198	220	22
Coarse Sand-Gravel	X	220	225	5
Brown Clay-Coarse Sand		225	230	5
Coarse Sand-Gravel	X	230	239	9

Date started 1-5, 1995
Date completed 1-13, 1995

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Bailed	40	4	1/2 HR

8. WELL CONSTRUCTION
Depth Drilled 239 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	50 Feet
9 7/8 Inches	50 Feet	239 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	239

Perforations:
Type perforation Sawed
Size perforation 3/32 x 3" x 6 Rows
From 159 feet to 179 feet
From 219 feet to 239 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 239 feet

9. WATER LEVEL
Static water level 96 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Bros Drilling (Contractor)
Address 162 N. ByBee Lane (Contractor)
Yerington Nev 89447
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed [signature] By driller performing actual drilling on site or contractor
Date 1-13-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627