WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49502
Permit No.
Basin 178

NOTICE OF INTENT NO.

1. OWNER Mike Botelho
MAILING ADDRESS 537 Pete Hencuchs Rd
Yerington, NV 89447
ADDRESS AT WELL LOCATION same

2. LOCATION SW ¼ SE ¼ Sec. 31 T. 14 N/S R. 26 E. Lyon County
PERMIT NO. (Issued by Water Resources) 14-381-15 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	8	8
Coarse sand/gravel				
fill		8	16	8
C. Sand/gravel w/				
rock fill		16	24	8
Brown clay/c. sand		24	30	6
C. sand/gravel fill		30	38	8
Clay dirt sand/gravel				
fill		38	54	16
Fine to coarse sand		54	56	2
Clay and coarse sand		56	90	34
Fine to coarse sand	X	90	110	20
Fine to coarse sand				
and sm gravel fill	X	110	130	20
Brown clay		130	133	3
Coarse sand/gravel				
w/rock	X	133	160	27
Fine to coarse sand				
w/ gravel	X	160	175	15
Coarse sand/gravel/				
rock	X	175	199	24

Date started 4-10, 19 95
Date completed 4-14, 19 95

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	5	½ hr.

8. WELL CONSTRUCTION
Depth Drilled 199 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10 5/8	0	199

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	199

Perforations:
Type perforation Sawed
Size perforation 3/32" X 3" X 6 rows
From 179 feet to 199 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 199 feet

9. WATER LEVEL
Static water level 60 feet below land surface
Artesian flow N/A G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Bros. Drilling (Contractor)
Address 162 N. Bybee Lane (Contractor)
Yerington, NV 89447
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 4-18-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627